

Foot candle (Light Level) recommendations.

TASK AREA	FOOTCANDLES
Corridors/Stairways/Restrooms	10-20
Storage Rooms	10-50
Conference Rooms	20-50
General Offices	50-100
Drafting/Accounting	100-200
Areas with VDTs	75
Classrooms	50-75
Cafeterias	50
Gymnasiums	30-50
Merchandising	30-150
Manufacturing Assemble	50-500
Parking Areas (uncovered)	1-2
Airports	
Hangar Aprons	1
Terminal Apron-Parking	0.5
Building Construction	
General Construction	10
Bulletin Boards	
Light Surfaces	20/50
Dark Surfaces	50/100
Loading Platforms	20
Parking Areas/Vehicular Traffic	
Low Activity	0.5
Medium Activity	1
High Activity	2
Railroad Yards	
Switch Points	2
Shipyards	
General	5
Storage Yards	201
Sports	
Baseball-Recreational	15/10
Basketball - High School	30
Basketball - Recreational	10
Playgrounds	5
Tennis Club	20